



防爆合格证

证号: GYJ17.1497X

由 Rotech Antriebselemente GmbH
(地址: Im Katzentach 16-18, 76275 Ettlingen, Germany)

制造的产品:

名称 限位开关模块

型号规格 ALB.....AZ....
Ex e ia II A / II B / II C T6 Gb
防爆标志 Ex d e II A / II B / II C T6 Gb
Ex nA ic II A / II B / II C T6 Gc
产品标准 Ex tD A21 IP65 T80°C
/

图样编号 /

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、GB 3836.4-2010、GB 3836.8-2014、GB 12476.1-2013、GB 12476.5-2013 标准, 特颁发此证。

本证书有效期: 2017年11月20日至2022年11月19日

备注 1. 安全使用注意事项见本证书附件。
2. 证书编号后缀“X”表明产品具有安全使用特殊条件, 内容见本证书附件。
3. 电气安全参数见本证书附件。

站长

国家级仪器仪表防爆安全监督检验站
颁发日期二〇一七年十一月二十日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO.GYJ17.1497X

This is to certify that the product

Limit switch module

manufactured by **Rotech Antriebselemente GmbH**
(Address: Im Katzentach 16-18, 76275 Ettlingen, Germany)

which model is **ALB.....AZ....**

Ex marking **Ex e ia IIA /IIB /IIC T6 Gb**
Ex d e IIA /IIB /IIC T6 Gb
Ex nA ic IIA /IIB /IIC T6 Gc
Ex tD A21 IP65 T80°C

product standard /

drawing number /

has been inspected and certified by NEPSI, and that it conforms
to **GB 3836.1-2010,GB 3836.2-2010,GB 3836.3-2010,GB 3836.4-2010,**
GB 3836.8-2014,GB 12476.1-2013,GB 12476.5-2013

This Approval shall remain in force until **2022.11.19**

Remarks **1.Conditions for safe use are specified in the attachment to this certificate.**
2.Symbol "X" placed after the certification number denotes specific conditions of use,
which are specified in the attachment to this certificate.
3.Safe parameters specified in the attachment to this certificate.

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date **2017.11.20**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.